



National Electric Power Regulatory Authority

Islamic Republic of Pakistan

2nd Floor, OPF Building, G-5/2, Islamabad

Ph: 9206500, 9207200, Fax: 9210215

E-mail: registrar@nepra.org.pk

Registrar

No. NEPRA/R/TCD.04/

4973-74

July 05, 2011

Chief Executive Officer
Faisalabad Electric Supply Company (FESCO)
Abdullahpur, Canal Bank Road,
Faisalabad.

Mian Muhammad Tayyab
Chief Executive Officer
Tayyab Textile Mills Limited
P-21/1, Bilal Road,
New Civil Line, Faisalabad

Subject:

**DECISION IN THE MATTER OF COMPLAINT FILED BY M/S TAYYAB
TEXTILE MILLS (PVT.) LIMITED UNDER SECTION 39 OF THE
REGULATION OF GENERATION, TRANSMISSION AND
DISTRIBUTION OF ELECTRIC POWER ACT, 1997 AGAINST
FAISALABAD ELECTRIC SUPPLY COMPANY REGARDING
EXTENSION OF LOAD.**

Complaint No. FESCO 04-2011

Please find enclosed the decision of Vice Chairman / Member (Consumer Affairs) on the subject matter for compliance within 60 days of the receipt of this letter by FESCO.

Encl:/As above

~Sd~

(Syed Safer Hussain)

July 05, 2011

Registrar

No. NEPRA/R/TCD.04/

4975

Forwarded for information, please.

Dy. Director (CAD)

cc

1. Chairman
2. V. Chairman / Member (Consumer Affairs)

[Handwritten signature]
05/07/11

[Handwritten signature]

BEFORE THE
NATIONAL ELECTRIC POWER REGULATORY AUTHORITY
(NEPRA)

Complaint No. 04-2011

M/s Tayyab Textile Mills (Pvt) Ltd Complainant

Versus

Faisalabad Electric Supply Company Ltd Respondent

Date of Hearing: May 3, 2011

Date of Decision: June 29, 2011

Before : Shaukat Ali Kundi (Vice Chairman/Member Consumer Affairs)

On behalf of:

Complainant: 1) Mr. Ashfaq Ahmed (GM Accounts).
2) Mr. Imran Rashad (GM Finance).

Respondent: 1) Syed Ashfaq Ahmed, Chief Engineer (Planning)
2) Mr. Akbar Ali, Deputy Manager (Planning).

IN THE MATTER OF COMPLAINT FILED BY M/S TAYYAB TEXTILE MILLS (PVT) LTD UNDER SECTION 39 OF THE REEGULATION OF GENERATION, TRANSMISSION AND DISTRIBUTION OF ELECTRIC POWER ACT, 1997 AGAINST FAISALABAD ELECTRIC SUPPLY COMPANY REGARDING EXTENSION OF LOAD.

ORDER

1. This Order shall dispose of the complaint of Director of M/S Tayyab Textile Mills (Pvt) Ltd (hereinafter referred to as "the Complainant") dated 29.01.2011 addressed to Faisalabad Electric Supply Company (hereinafter referred to as "the Respondent") the copy of which was also endorsed to National Electric Power Regulatory Authority (hereinafter referred to as "NEPRA or the Authority").
2. The Complainant in his aforesaid complaint stated that they applied to the Respondent for extension of load from 1700 kW to 2480 kW from their existing feeder i.e Tayyab Textile Feeder

emanating from Chiniot Grid Station. It was further stated that at present 3200 kW load is running on 11 kV Tayyab Textile Feeder and after transfer of 1500 kW load of M/s Tahir Rafique Mills (Pvt) Ltd to Kamalpur grid, the load on Tayyab Textile feeder would diminish by 1500 kW. The Respondent instead of issuing demand notice for security for 780 kW (2480 kW-1700kW) issued demand notice for new connection from Kamalpur Grid station. After deposit of capital cost amounting to Rs. 13,06,478/-, a credit of Rs. 6,61,710/- was given to them for their existing feeder emanated from 132 kV Chiniot Grid station which was laid down by them at their own expenses. The complainant requested for extension of 780 kW load from their existing feeder which was installed on their expenses and which is working satisfactorily. The complainant further submitted that if it is not possible to allow the extension from their existing feeder, then the same extension may be allowed from the proposed 11 kV feeder from the Kamalpur Grid station and M/s Tahir Rafique Mills (Pvt) Ltd has no objection if Tayyab Textiles is adjusted on its feeder and also that they may be allowed for dismantling of their line by themselves as the same was procured/installed by them after completion of all departmental formalities.

3. The Consumer Affairs Division (CAD), Nepra vide its letter No. TCD 04/562-2011 dated 09.02.2011 directed the Respondent to file its parawise reply / investigation report specifying its admission or denial about the allegations leveled in the said complaint within 20 (Twenty) days of the receipt of that notice. The Respondent in its report dated 26.02.2011 stated that initially 11 kV independent feeder from 132 kV Chiniot Grid Station with Osprey conductor was approved on 15-8-1992 and the consumer got completed the work through his contractor. The consumer applied for extension of load from 1700 kW to 2100 kW (net extension of 400 kW) on 7-12-2009, accordingly the case was approved and demand notice amounting to Rs. 24,94,205/- was issued on 11-5-2010 but the same was not paid by the consumer and he again requested for extension of load from 1700 kW to 2480 kW (net extension of 780 kW). A new estimate amounting to Rs. 13,06,478/- was prepared and demand notice has been issued on 19-1-2011 for feeding source as 11 kV line from 132 kV Kamalpur Grid Station after giving credit of Rs. 6,61,710/- for dismantling of existing 11 kV feeder emanating from Chiniot Grid station by applying 90% depreciation @ 5% per year considering 20 years useful life since 27-12-1992 as per rules. The respondent further stated that the payment of demand notice is awaited.

4. To further explore the matter, a hearing was fixed at NEPRA Head Office on May 03, 2011 in which both the parties participated. The complainant and the Respondent reiterated almost the same contentions in the aforesaid hearing as contained in their complaint and report respectively. The respondent was of the view that the complainant's connection is being fed through 11 kV