

## **National Electric Power Regulatory Authority**

### Islamic Republic of Pakistan

NEPRA Tower, Attaturk Avenue (East) G-5/1, Islamabad Phone: 9206500, Fax: 2600026

Website: www.nepra.org.pk, Email: info@nepra.org.pk

No. NEPRA/R/NMC-2092/ 3/86-89

March 06, 2024

**Medical Superintendent** C/O Dr. Khalid Majeed D.H.Q Hospital, Narowal. Contact No. 0311-7011684

Subject:

Distributed Generation Concurrence No. NMC/2092/2024

Concurrence Application No. NMC-2092

Medical Superintendent C/O Dr. Khalid Majeed, GEPCO

Reference:

GEPCO's letter No. 733-37 dated 15.02.2024(received on 26.02.2024).

Enclosed please find herewith Distributed Generation Concurrence No. NMC/2092/2024 granted by the National Electric Power Regulatory Authority to Medical Superintendent C/O Dr. Khalid Majeed for 357.000 kW photo voltaic solar based distributed generation facility located at D.H.Q Hospital, Narowal, pursuant to NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015.

Please quote above mentioned Distributed Generation Concurrence No. for future 2. correspondence.

**Enclosure:** Distributed Generation Concurrence

(NMC/2092/2024)

(Engr. Mazhar Iqbal Ranjha)

### Copy to:

- 1. Managing Director, Private Power Infrastructure Board (PPIB), Ground & 2nd Floor, Emigration Tower, Sector G/8-1, Islamabad.
- 2. Chief Executive Officer, Gujranwala Electric Power Company Ltd., 565/A, Model Town, G.T. Road, Gujranwala
- 3. Director General, Environmental Protection Department, Government of Punjab, National Hockey Stadium, Ferozpur Road, Lahore Cantt.

# National Electric Power Regulatory Authority (NEPRA)

### Islamabad-Pakistan

### **DISTRIBUTED GENERATION CONCURRENCE**

No. NMC/2092/2024

The Authority in terms of Section 14B (5) of the Regulation of Generation, Transmission and Distribution of Electric Power Act (XL of 1997) (the "Act"), hereby grants Concurrence for the Distributed Generation facility to be set up in the name of **Medical Superintendent C/O Dr. Khalid Majeed** having consumer **Reference Number 27** 12511 1349009 U at D.H.Q Hospital Narowal.

- The beneficiary shall abide by the provisions under the Act and NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015, as amended from time to time.
- 3. The technical parameters of the Net Metering arrangements are as under:-

3 14 4		The second secon		
(i).	Source of Generation	Solar Energy		
(ii).	Size of Distributed Generation Facility	.357.000 KW		
9.	Inverter Information			
(iii).	Manufacture	SOLIS		
	Model No.	SOLIS 110KTL 5G x 2,		
5 <u>8.</u> 20		SOLIS 80KTL 5G x 2		
(iv).	Vendor/Installer	SOLAR TECH (PVT.)		
49 48.33		LTD.		
(v).	Generation Type	PV SOLAR		

			4.5		
				<sup>7</sup> ) years and will exp	
<u><i>05</i></u> day	of Max,	2031 and may	be renewed as	stipulated under the A	Act o
the relevant	Regulations framed	thereafter.			
				lo de la companya de	9. 5.54
<b>5</b> . 1	This Concurrence is	given under my	hand on <u>06</u>	day of Mar.	Two
<u>Thousan</u>	d & Twenty Fou	ır.	NER PA		Ŋ
H		(\$0)	NER REGILE		r i
Registrar		M FE	IEPRA R		