

National Electric Power Regulatory Authority

Islamic Republic of Pakistan

NEPRA Tower, Attaturk Avenue (East) G-5/1, Islamabad Phone: 9206500, Fax: 2600026

Website: www.nepra.org.pk, Email: info@nepra.org.pk

No. NEPRA/R/NMC-4230//3226-29

July 08, 2024

Main Building DHQ Hospital

C/o Dr. Khaliq Dad DHQ Hospital, Mandi Bahauddin. Contact No. 0315-8003221

Subject:

Distributed Generation Concurrence No. NMC/4230/2024

Concurrence Application No. NMC-4230 Main Building DHQ Hospital, GEPCO

Reference:

GEPCO's letter No. 3906-10 dated 26.06.2024 (received on 01.07.2024).

Enclosed please find herewith Distributed Generation Concurrence No. NMC/4230/2024 granted by the National Electric Power Regulatory Authority to Main Building DHQ Hospital for 235.410 kW photo voltaic solar based distributed generation facility located at DHQ Hospital, Mandi Bahauddin, pursuant to NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015.

Please quote above mentioned Distributed Generation Concurrence No. for future 2. correspondence.

Enclosure: Distributed Generation Concurrence

(NMC/4230/2024)

(Engr. Mazhar Iqbal Ranjha)

Copy to:

- 1. Managing Director, Private Power Infrastructure Board (PPIB), Ground & 2nd Floor, Emigration Tower, Plot No. 10, Mauve Area, Sector G/8-1, Islamabad.
- 2. Chief Executive Officer, Gujranwala Electric Power Company Ltd., 565/A, Model Town, G.T. Road, Gujranwala
- 3. Director General, Environmental Protection Department, Government of Punjab, National Hockey Stadium, Ferozpur Road, Lahore Cantt.

National Electric Power Regulatory Authority (NEPRA)

Islamabad-Pakistan

DISTRIBUTED GENERATION CONCURRENCE

No. NMC/4230/2024

The Authority in terms of Section 14B (5) of the Regulation of Generation, Transmission and Distribution of Electric Power Act (XL of 1997) (the "Act"), hereby grants Concurrence for the Distributed Generation facility to be set up in the name of Main Building DHQ Hospital C/O Dr. Khaliq Dad having consumer Reference Number 30 12613 1599601 R at Mandi Baha Uddin.

- 2. The beneficiary shall abide by the provisions under the Act and NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015 during the currency of the Net Metering Generation facility.
- 3. The technical parameters of the Net Metering arrangements are as under:-

(i).	Source of Generation	Solar Energy
(ii).	Size of Distributed Generation Facility	235.410 KW
	Inverter Information	
(iii).	Manufacture	HUAWEI
()	Model No.	SUN2000-115KTL-M2,
		SUN2000-3/4/5/6/8/10KTL-M0
(iv).	Vendor/Installer	PANTERA ENERGY (PVT.)
•		LTD.
(v).	Generation Type	PV SOLAR

5.	This Concurrence	is given under my hand on $08^{\frac{\pi}{\text{day}}}$ of $\frac{\text{July}}{\text{Two}}$	<u>0</u>
the rele	vant Regulations fram	1.	
	/		r
4#	This Concurrence	is issued for a period of seven (07) years and will expire on 2031 and may be renewed as stipulated under the Act of	-

Registrar

May