



REGISTRAR

National Electric Power Regulatory Authority
Islamic Republic of Pakistan

NEPRA Tower, Attaturk Avenue (East) G-5/1, Islamabad
Phone: 2013200, Fax: 2600026

Website: www.nepra.org.pk, Email: info@nepra.org.pk

No. NEPRA/R/NMC-1455-I/ 28816-19

November 28, 2025

GM Plant FCCL
C/o Wasif Saeed,
Near Nika Bridge,
Fateh Jang.
Contact No. 0300-0511466

Subject: Distributed Generation Concurrence No. NMC/1455-I/2025
Concurrence Application No. NMC-1455-I
GM Plant FCCL, IESCO

Reference: IESCO's Application No. 20668-71 dated 16.10.2025 (received on 27.10.2025).

Enclosed please find herewith Distributed Generation Concurrence No. NMC/1455-I/2025 granted by the National Electric Power Regulatory Authority to GM Plant FCCL for 250.000 kW photo voltaic solar based distributed generation facility to be set up at Near Nika Bridge, Fateh Jang, pursuant to NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015.

2. Please quote above mentioned Distributed Generation Concurrence No. for future correspondence.

Enclosure: **Distributed Generation Concurrence**
(NMC/1455-I/2025)


(Wasim Anwar Bhinder)

Copy to:

1. Managing Director, Private Power Infrastructure Board (PPIB), Ground & 2nd Floor, Emigration Tower, Plot No. 10, Mauve Area, Sector G/8-1, Islamabad.
2. Chief Executive Officer, Islamabad Electric Supply Company Limited, IESCO Head Office, Street 40, Sector G-7/4, Islamabad
3. Director General, Pakistan Environmental Protection Agency, Plot No. 41, Street No. 6, H-8/2, Islamabad

National Electric Power Regulatory Authority
(NEPRA)

Islamabad–Pakistan

DISTRIBUTED GENERATION CONCURRENCE

No. NMC/1455-I/2025

The Authority under Regulation-4 of NEPRA (Alternative & Renewable Energy) Distributed Generation and Net metering Regulations, 2015 (the "A&RE Regulations") grants Distributed Generation Concurrence to ***GM Plant FCCLC/o Wasif Saeed** having consumer **Reference Number 27 14253 4482105 U** located at Near Naika Bridge Fateh Jhang. This Concurrence is being issued in lieu of the earlier Concurrence dated January 05, 2024 to incorporate the enhancement in the capacity from 83.935 KW to 250.00 KW. However its term of seven (07) years will remain the same and expire on 04th day of January 2031.

2. The beneficiary shall abide by the provisions under the A&RE Regulations, as amended from time to time.

3. The technical parameters of the Net Metering arrangements are as under:-

(i).	Source of Generation	Solar Energy		
(ii).	Size of Distributed Generation Facility	Phase-I	Phase-II	Total
		83.935 KW	166.065 KW	250.00 KW
(iii).	Inverter Information			
	Manufacture	Phase-I	Phase-II	
		FRONUIS / SUNGROW	SUNGROW	
(iv).	Model No.	DMT 20KW / SG60KTL		SG250HX
	Vendor/Installer	RENEWABLE STARS (PVT.) LTD.		
(v).	Generation Type	PV SOLAR		

4. This modified Concurrence is given under my hand on ²⁸ 28 day of Nov,
Two Thousand & Twenty Five.

Wasif Saeed

Registrar

*The Distributed Generation Net Metering Concurrence NMC/1455/2024 dated January 05, 2024 issued earlier for 83.935 KW in the name of GM Plant FCCL C/o Wasif Saeed hereby stands cancelled.

