

REGISTRAR

# **National Electric Power Regulatory Authority**

## Islamic Republic of Pakistan

NEPRA Tower, Attaturk Avenue (East) G-5/1, Islamabad Phone: 9206500, Fax: 2600026

Website: www.nepra.org.pk, Email: info@nepra.org.pk

No. NEPRA/R/NMC-400-1/ 30471-74

July 24, 2025

Maqbool Ahmad

Marral Textile Mills Kamon Gil Road, Saricheembah Contact No. 0300-8401885

Subject:

Distributed Generation Concurrence No. NMC/400-I/2025

Concurrence Application No. NMC-400-I

Maqbool Ahmad, LESCO

Reference:

LESCO's letter No. 23252-58 dated 11.07.2025 (received on 17.07.2025).

Enclosed please find herewith Distributed Generation Concurrence No. NMC/400-I/2025 granted by the National Electric Power Regulatory Authority to Maqbool Ahmad for 999,750 KW photo voltaic solar based distributed generation facility at Marral Textile Mills Kamon Gil Road, Saricheembah, pursuant to NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015.

2. Please quote above mentioned Distributed Generation Concurrence No. for future correspondence.

Enclosure: Distributed Generation Concurrence (NMC/400-I/2025)

#### Copy to:

- 1. Managing Director, Private Power Infrastructure Board (PPIB), Ground & 2<sup>nd</sup> Floor, Emigration Tower, Plot No. 10, Mauve Area, Sector G/8-1, Islamabad.
- 2. Chief Executive Officer, Lahore Electric Supply Company Limited, 22-A, Queens Road, Lahore.
- 3. Director General, Environmental Protection Department, Government of Punjab, National Hockey Stadium, Ferozepur Road, Lahore

### **National Electric Power Regulatory Authority** (NEPRA)

#### Islamabad-Pakistan

#### **DISTRIBUTED GENERATION CONCURRENCE**

No. NMC/400-I/2025

The Authority under Regulation-4 of NEPRA (Alternative & Renewable Energy) Distributed Generation and Net metering Regulations, 2015 (the "A&RE Regulations") grants Distributed Generation Concurrence to \*Maqbool Ahmad having consumer Reference Number 24 11919 9003000 U located at Marral Textile Mills Kamon Gil Road, Saricheembah. This Concurrence is being issued in lieu of the earlier Concurrence dated August 09, 2023 to incorporate the enhancement in the capacity from 499.950 KW to 999.750 KW. However its term of seven (07) years will remain the same and expire on 08th day of August 2030.

- 2. The beneficiary shall abide by the provisions under the A&RE Regulations, as amended from time to time.
- 3. The technical parameters of the Net Metering arrangements are as under:-

(i).	Source of Generation	Solar Energy
(ii).	Size of Distributed Generation Facility	999.750 KW
(iii).	Inverter Information	
	Manufacture	SUNGROW
	Model No.	SG110CX*4 / SG125CX P2
(iv).	Vendor/Installer	SB ELECTRONICS ENGINEERING &
		CONTROL (PVT.) LTD.
(v).	Generation Type	PV SOLAR

The Concurrence may be renewed subject to the A&RE Regulations. 4.

This Concurrence is given under my hand on day of 5.

**Thousand & Twenty Five.** 

\*The Distributed Generation Net Metering Concum (c) ce NMC/400/20/28 reby stands cancelled. earlier for 499.950 KW in the name of Maqbool Ahm

dated August 09, 2023 issued