

National Electric Power Regulatory Authority

Islamic Republic of Pakistan

NEPRA Tower, Attaturk Avenue (East) G-5/1, Islamabad Phone: 92013200, Fax: 2600026

Website: www.nepra.org.pk, Email: info@nepra.org.pk

No. NEPRA/R/NMC-1270-I/5099194

December 18, 2025

Mr. Shakeel Ahmed, Mr. Jameel Ahmad Kotli Pathana Doliey Wala Road, Kasur Contact No. 0300-6580000

Subject:

Distributed Generation Concurrence No. NMC/1270-I/2025

Concurrence Application No. NMC-1270-I

Mr. Shakeel Ahmed, Mr. Jameel Ahmad, LESCO

Reference:

LESCO's letter No. 34816-21 dated 31.10,2025 (received on 04.11.2025).

Enclosed please find herewith Distributed Generation Concurrence No. NMC/1270-I/2025 granted by the National Electric Power Regulatory Authority to Mr. Shakeel Ahmed, Mr. Jameel Ahmad for 230.260 KW photo voltaic solar based distributed generation facility at Kotli Pathana Doliey Wala Road, Kasur, pursuant to NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015.

2. Please quote above mentioned Distributed Generation Concurrence No. for future correspondence.

Enclosure: Distributed Generation Concurrence (NMC/1270-I/2025)

Copy to:

- 1. Managing Director, Private Power Infrastructure Board (PPIB), Ground & 2nd Floor, Emigration Tower, Plot No. 10, Mauve Area, Sector G/8-1, Islamabad.
- 2. Chief Executive Officer, Lahore Electric Supply Company Limited, 22-A, Queens Road, Lahore.
- 3. Director General, Environmental Protection Department, Government of Punjab, National Hockey Stadium, Ferozepur Road, Lahore

National Electric Power Regulatory Authority (NEPRA)

Islamabad-Pakistan

DISTRIBUTED GENERATION CONCURRENCE

No. NMC/1270-I/2025

The Authority under Regulation-4 of NEPRA (Alternative & Renewable Energy) Distributed Generation and Net metering Regulations, 2015 (the "A&RE Regulations") grants Distributed Generation Concurrence to * Mr. Shakeel Ahmed, Mr. M. Jameel Ahmad having consumer Reference Number 24 11721 2439005 R located at Kotli Pathana Doliey Wala Road, Kasur. This Concurrence is being issued in lieu of the earlier Concurrence dated December 08, 2023 to incorporate the enhancement in the capacity from 110.090 KW to 230.260 KW. However its term of seven (07) years will remain the same and expire on 07th day of December 2030.

- The beneficiary shall abide by the provisions under the A&RE Regulations, as 2. amended from time to time.
- 3. The technical parameters of the Net Metering arrangements are as under:-

| .(i). | Source of Generation | Solar Energy | | | | |
|--------|--------------------------------|-------------------|----------|-------------------|------------|--|
| (ii). | Size of Distributed Generation | Phase-I | Phase-II | | Total | |
| | Facility | 110.090 KW | 120.170 | KW | 230.260 KW | |
| ٠. | Inverter Information | | | | | |
| (iii). | Manufacture | Phase-I | P | | Phase-II | |
| | | HUAWEI | | HUAWEI | | |
| | Model No. | SUN2000-115KTL-M2 | | SUN2000-110KTL-M0 | | |
| (iv). | Vendor/Installer | ZERO CA | RBON | POWER | R SOLAR 99 | |
| | | (PVT.) LTD. | | : | a.* | |
| (v). | Generation Type | PV SOLAR | | | | |

4. This modified Concurrence is given under my hand on 12" day of 1)ec

Two Thousand & Twenty Five.

Mu Leway

Registrar

*The Distributed Generation Net Metering Concurrence NMC/1270/2023 dated December 08, earlier for 110.090 KW in the name of Mr. Shakeel Ahmed, Mr. M. James Amad hereby stard 2023 issued cancelled.

NEPRA