

## **National Electric Power Regulatory Authority**

### Islamic Republic of Pakistan

NEPRA Tower, Attaturk Avenue (East) G-5/1, Islamabad Phone: 2013200, Fax: 2600026

Website: www.nepra.org.pk, Email: Registrar@nepra.org.pk

No. NEPRA/R/NMC-6269-I/ 44981-84

October 31, 2025

Mr. Muhammad Maqbool

Chak No. 130-15/L, Bypass Road, Mian Channu. Contact No. 0307-5423564

Subject:

Distributed Generation Concurrence No. NMC/6269-I/2025

Concurrence Application No. NMC-6269-I

Mr. Muhammad Magbool, MEPCO

MEPCO's letter No. 84089-91 dated 17.10.2025 (received on 23.10.2025). Reference:

Enclosed please find herewith Distributed Generation Concurrence No. NMC/6269-I/2025 granted by the National Electric Power Regulatory Authority to Mr. Muhammad Maqbool for 159.705 kW photo voltaic solar based distributed generation facility at Chak No. 130-15/L, Bypass Road, Mian Channu, pursuant to NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015.

Please quote above mentioned Distributed Generation Concurrence No. for future 2. correspondence.

**Enclosure:** Distributed Generation Concurrence

(NMC/6269-I/2025)

(Wasim Anwar Bhinder)

#### Copy to:

- 1. Managing Director, Private Power Infrastructure Board (PPIB), Ground & 2nd Floor, Emigration Tower, Plot No. 10, Mauve Area, Sector G/8-1, Islamabad.
- Chief Executive Officer, Multan Electric Power Company Limited (MEPCO), MEPCO Head Quarters, Khanewal Road, Multan.
- 3. Director General, Environment Protection Department, Government of Punjab, National Hockey Stadium, Ferozepur Road, Lahore.

# National Electric Power Regulatory Authority (NEPRA)

### Islamabad-Pakistan

### **DISTRIBUTED GENERATION CONCURRENCE**

No. NMC/6269-I/2025

The Authority under Regulation-4 of NEPRA (Alternative & Renewable Energy) Distributed Generation and Net metering Regulations, 2015 (the "A&RE Regulations") grants Distributed Generation Concurrence to \*Mr. Muhammad Maqbool having consumer Reference Number 27 15935 0000402 U located at Chak No.130-15L, Bypass Road, Mian Channu. This Concurrence is being issued in lieu of the earlier Concurrence dated October 02, 2024 to incorporate the enhancement in the capacity from 94.540 KW to 159.705 KW. However its term of seven (07) years will remain the same and expire on 01st day of October 2031.

- 2. The beneficiary shall abide by the provisions under the A&RE Regulations, as amended from time to time.
- 3. The technical parameters of the Net Metering arrangements are as under:-

(i).	Source of Generation	Solar Energy				
(ii).	Size of Distributed Generation	Phase-I	Phase-II		Total	
	Facility	94.540 KW	65.165 KW		159.705 KW	
	Inverter Information					
(iii).	Manufacture	Phase-I	Phase-I		Phase-II	
(111).			HUA	WEI		
	Model No.	HUAWEI-115KTL		HUAWEI 60KW		
(iv).	Vendor/Installer	ACCUTECH INTERNATIONAL		HUSSAIN SOLAR		
				NETMETERING		
				PROJ	ECT SYSTEM	
(v).	Generation Type	PV SOLAR				

4. This modified Concurrence is given under my hand on 31 day octof

Two Thousand & Twenty Five.

Warm tuman

Registrar

\*The Distributed Generation Net Metering Concurrence NMC/6269/2024 dated October 02, 2024 issued earlier for 94.540 KW in the name of Muhammad Maqbool hereby stands cancelled.

NEPRA AUTHORITY