

National Electric Power Regulatory Authority Islamic Republic of Pakistan

NEPRA Tower, Attaturk Avenue (East) G-5/1, Islamabad Phone: 9206500, Fax: 2600026

Website: www.nepra.org.pk, Email: info@nepra.org.pk

No. NEPRA/R/NMC-5960// 2/69/-94

September 19, 2024

Mr. Shah Jehan Afridi Medical Center, Tehkal Payan, Peshawar. Contact No. 0314-4979726

Subject:

Distributed Generation Concurrence No. NMC/5960/2024

Concurrence Application No. NMC-5960

Mr. Shah Jehan, PESCO

Reference:

PESCO's letter No. 1600-03 dated 30.08.2024 (received on 09.09.2024).

Enclosed please find herewith Distributed Generation Concurrence No. NMC/5960/2024 granted by the National Electric Power Regulatory Authority to Mr. Shah Jehan for 198.360 kW photo voltaic solar based distributed generation facility located at Afridi Medical Center, Tehkal Payan, Peshawar, pursuant to NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015.

2. Please quote above mentioned Distributed Generation Concurrence No. for future correspondence.

Enclosure: **Distributed Generation Concurrence** (NMC/5960/2024)

(Syed Zawar Haider)

Copy to:

- 1. Managing Director, Private Power Infrastructure Board (PPIB), Ground & 2nd Floor, Emigration Tower, Sector G/8-1, Islamabad.
- 2. Chief Executive Officer, Peshawar Electric Supply Company Limited, PESCO 166 WAPDA House, Shami Road, Peshawar.
- 3. Director General, Environmental Protection Agency (EPA), 3rd Floor, Old Courts Building, Khyber Road, Peshawar.

National Electric Power Regulatory Authority (NEPRA)

Islamabad-Pakistan

DISTRIBUTED GENERATION CONCURRENCE

No. NMC/5960/2024

The Authority in terms of Section 14B (5) of the Regulation of Generation, Transmission and Distribution of Electric Power Act (XL of 1997) (the "Act"), hereby grants Concurrence for the Distributed Generation facility to be set up in the name of **Mr. Shah**Jehan having consumer Reference Number 30 26133 0016203 U at Afridi Medical Centre Tehkal Payan, Peshawar.

- 2. The beneficiary shall abide by the provisions under the Act and NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015, as amended from time to time.
- 3. The technical parameters of the Net Metering arrangements are as under:-

(i).	Source of Generation	Solar Energy
(ii).	Size of Distributed Generation Facility	198.360 KW
(iii).	Inverter Information	
	Manufacture	SINENG
	Model No.	MAC 60KTL3-X LV
(iv).	Vendor/Installer	GROWATT PK (PVT.) LTD.
(v).	Generation Type	PV SOLAR

	urrence is issued for a period of seven (07) years an	
18 day of Scy	2031 and may be renewed as stipulated u	ınder the Act or
the relevant Regulations	is framed thereafter.	

5. This Concurrence is given under my hand on 19 day of Two Thousand & Twenty Four.

And I would be

Régistrar



Q.

S.

Unt