



REGISTRAR

National Electric Power Regulatory Authority
Islamic Republic of Pakistan

NEPRA Tower, Attaturk Avenue (East) G-5/1, Islamabad

Phone: 2013200, Fax: 2600026

Website: www.nepra.org.pk, Email: info@nepra.org.pk

No. NEPRA/R/NMC-7410-I/ 39441-44

September 17, 2025

Director of Institute IRNUM Hospital
IRNUM Hospital,
Peshawar.
Contact No. 0333-4446498


Subject: Distributed Generation Concurrence No. NMC/7410-I/2025
Concurrence Application No. NMC-7410-I
Director of Institute IRNUM Hospital, PESCO

Reference: PESCO's letter No. 7595-97 dated 06.08.2025 (received on 28.08.2025).

Enclosed please find herewith Distributed Generation Concurrence No. NMC/7410-I/2025 granted by the National Electric Power Regulatory Authority to Director of Institute IRNUM Hospital for 499.105 kW photo voltaic solar based distributed generation facility at IRNUM Hospital, Peshawar pursuant to NEPRA (Alternative & Renewable Energy) Distributed Generation and Net Metering Regulations, 2015.

2. Please quote above mentioned Distributed Generation Concurrence No. for future correspondence.

Enclosure: **Distributed Generation Concurrence**
(NMC/7410-I/2025)


(Iftikhar Ali Khan)

Copy to:

1. Managing Director, Private Power Infrastructure Board (PPIB), Ground & 2nd Floor, Emigration Tower, Sector G/8-1, Islamabad.
2. Chief Executive Officer, Peshawar Electric Supply Company Limited, PESCO 166 WAPDA House, Shami Road, Peshawar.
3. Director General, Environmental Protection Agency (EPA), 3rd Floor, Old Courts Building, Khyber Road, Peshawar.

National Electric Power Regulatory Authority
(NEPRA)

Islamabad-Pakistan

DISTRIBUTED GENERATION CONCURRENCE

No. NMC/7410-I/2025

The Authority under Regulation-4 of NEPRA (Alternative & Renewable Energy) Distributed Generation and Net metering Regulations, 2015 (the "A&RE Regulations") grants Distributed Generation Concurrence to * **Director of Institute IRNUM Hospital** having consumer **Reference Number 31 26133 0004800 U** located at Director Institute IRNUM Hospital, Peshawar. This Concurrence is being issued in lieu of the earlier Concurrence dated November 08, 2024 to incorporate the enhancement in the capacity from 94.055 KW to 499.105 KW. However its term of seven (07) years will remain the same and expire on 07th day of November 2031.

2. The beneficiary shall abide by the provisions under the A&RE Regulations, as amended from time to time.

3. The technical parameters of the Net Metering arrangements are as under:-

(i).	Source of Generation	Solar Energy		
(ii).	Size of Distributed Generation Facility	Phase-I	Phase-II	Total
		94.055 KW	405.050 KW	499.105 KW
(iii).	Inverter Information			
	Manufacture	Phase-I		Phase-II
		SUNGROW / SOLIS		FOX
	Model No.	SG33CX / S5-GC50K		R-SERIES 125KW*3
(iv).	Vendor/Installer	GREEN EDGE ENGINEERING (PVT.) LTD.		
(v).	Generation Type	PV SOLAR		

4. This modified Concurrence is given under my hand on 17th day of Two Thousand & Twenty Five.

Registrar

*The Distributed Generation Net Metering Concurrence NMC/7410-I/2024 dated November 08, 2024 issued earlier for 94.055 KW in the name of Director of Institute IRNUM Hospital hereby stands cancelled.

