

Details of Generation Capacity (MW), Daily Energy Generation (GWh) and % age Plant Utilization

IPPs Bagasse

Chiniot Power Limited (CPL)

January , 2025

Days	Capacity (MW)		Load (MW)		Generation (GWh)	Energy %
	Installed	Dependable	Max	Min		W.r.t Dep. Cap
1	63	63	42	32	0.91	59.94
2	63	63	41	38	0.95	62.54
3	63	63	42	36	0.95	62.57
4	63	63	41	40	0.96	63.45
5	63	63	41	33	0.90	59.44
6	63	63	41	21	0.82	54.43
7	63	63	38	30	0.87	57.54
8	63	63	37	36	0.86	56.97
9	63	63	40	25	0.89	58.93
10	63	63	41	40	0.97	63.88
11	63	63	41	24	0.88	58.30
12	63	63	41	40	0.97	64.17
13	63	63	42	28	0.95	62.67
14	63	63	41	40	0.99	65.15
15	63	63	41	0	0.43	28.17
16	63	63	41	0	0.34	22.68
17	63	63	41	40	0.98	64.86
18	63	63	41	41	0.98	64.87
19	63	63	42	22	0.95	63.03
20	63	63	42	22	0.96	63.77
21	63	63	42	40	0.97	63.89
22	63	63	41	39	0.96	63.60
23	63	63	40	27	0.93	61.22
24	63	63	39	39	0.92	61.12
25	63	63	41	22	0.90	59.35
26	63	63	39	28	0.92	60.76
27	63	63	40	20	0.92	60.58
28	63	63	39	20	0.91	60.21
29	63	63	39	30	0.84	55.70
30	63	63	32	31	0.78	51.59
31	63	63	39	30	0.77	51.17
Total	63	63	--	--	27.32	58.28