

Details of Generation Capacity (MW), Daily Energy Generation (GWh) and % age Plant Utilization

Hydel Power Projects

Tarbela Hydropower Project (WAPDA)

May , 2025

Days	Capacity (MW)		Load (MW)		Generation (GWh)	Energy %
	Installed	Dependable	Max	Min		W.r.t Dep. Cap
1	3,478	3,478	1,962	850	29.14	34.91
2	3,478	3,478	1,840	560	29.77	35.67
3	3,478	3,478	1,510	390	21.59	25.86
4	3,478	3,478	1,350	580	21.41	25.65
5	3,478	3,478	1,330	520	21.67	25.96
6	3,478	3,478	2,375	490	26.78	32.08
7	3,478	3,478	2,372	555	29.17	34.94
8	3,478	3,478	1,924	775	32.61	39.07
9	3,478	3,478	1,924	610	31.24	37.42
10	3,478	3,478	2,416	530	32.45	38.87
11	3,478	3,478	2,760	976	42.33	50.71
12	3,478	3,478	2,501	875	41.65	49.90
13	3,478	3,478	2,460	480	33.31	39.90
14	3,478	3,478	2,592	800	38.20	45.76
15	3,478	3,478	2,296	770	33.94	40.65
16	3,478	3,478	2,592	650	29.73	35.62
17	3,478	3,478	2,908	880	43.50	52.11
18	3,478	3,478	2,928	840	49.40	59.18
19	3,478	3,478	2,928	1,860	62.62	75.02
20	3,478	3,478	2,950	1,280	54.38	65.14
21	3,478	3,478	2,940	1,874	64.05	76.73
22	3,478	3,478	2,924	2,310	63.45	76.01
23	3,478	3,478	2,944	2,324	62.18	74.49
24	3,478	3,478	2,892	956	55.44	66.42
25	3,478	3,478	3,008	2,428	70.54	84.51
26	3,478	3,478	3,010	2,707	71.65	85.83
27	3,478	3,478	3,024	2,758	71.29	85.41
28	3,478	3,478	3,040	2,526	71.38	85.51
29	3,478	3,478	3,058	2,452	70.12	84.00
30	3,478	3,478	3,061	2,312	70.75	84.76
31	3,478	3,478	3,060	2,220	65.16	78.06
Total	3,478	3,478	--	--	1,440.87	55.68